



Legislation Details (With Text)

File #:	CB 119248	Version:	2	Name:	CB 119248
Type:	Ordinance (Ord)	Status:	Passed	In control:	City Clerk
On agenda:	5/21/2018				
Final Action:	6/1/2018	Ord. No.	Ord 125588		
Title:	AN ORDINANCE amending the 2015 Seattle Building Code as adopted by Ordinance 125161; allowing the height limitation increase for Occupancy Group R-2 of Type IIIA construction be increased to six stories and 75 feet where all specified provisions are met.				
Sponsors:	Rob Johnson				
Indexes:					
Attachments:	1. Mayor's Letter on Returning Bill Unsigned 119248, 2. Summary and Fiscal Note, 3. Presentation (05/16/18), 4. CB 119248 v2 Proposed Amendments (added 5/16/18), 5. Signed Ordinance 125588, 6. Affidavit of Publication				

Date	Ver.	Action By	Action	Result
6/1/2018	2	City Clerk	attested by City Clerk	
6/1/2018	2	Mayor	returned	
6/1/2018	2	Mayor	returned unsigned	
5/23/2018	2	City Clerk	submitted for Mayor's signature	
5/21/2018	1	City Council	passed	Pass
5/16/2018	1	Planning, Land Use, and Zoning Committee	pass as amended	Pass
5/7/2018	1	City Council	referred	
11/21/2017	1	Council President's Office	sent for review	
11/14/2017	1	City Clerk	sent for review	
11/14/2017	1	Mayor	Mayor's leg transmitted to Council	

CITY OF SEATTLE

ORDINANCE _____

COUNCIL BILL _____

AN ORDINANCE amending the 2015 Seattle Building Code as adopted by Ordinance 125161; allowing the height limitation increase for Occupancy Group R-2 of Type IIIA construction be increased to six stories and 75 feet where all specified provisions are met.

BE IT ORDAINED BY THE CITY OF SEATTLE AS FOLLOWS:

Section 1. Section 510 of the 2015 Seattle Building Code, enacted by Ordinance 125161, is amended as follows:

SECTION 510

SPECIAL PROVISIONS

510.1 General. The provisions in Sections 510.2 through 510.10 shall permit the use of special conditions that are exempt from, or modify, the specific requirements of this chapter regarding the allowable *building heights* and *areas of buildings* based on the occupancy classification and type of construction, provided the special condition complies with the provisions specified in this section for such condition and other applicable requirements of this code. The provisions of sections 510.2 through ~~((510.8))~~ 510.7 are to be considered independent and separate from each other.

Interpretation I510: Sections 510.2 through ~~((510.8))~~ 510.7 are not permitted to be used in combination with each other. Sections 510.8 through 510.10 are permitted to be used in combination with Section 510.2.

510.2 Horizontal building separation allowance. A *building* shall be considered as separate and distinct *buildings* for the purpose of determining area limitations, continuity of *fire walls*, limitation of number of *stories* and type of construction where all of the following conditions are met:

1. The *buildings* are separated with a *horizontal assembly* having a *fire-resistance rating* of not less than 3 hours.
2. The building below and including the *horizontal assembly* is of Type IA construction.
3. *Shaft, stairway, ramp* and escalator enclosures through the *horizontal assembly* shall have not less than a 2-hour *fire-resistance rating* with opening protectives in accordance with Section 716.5.

Exception: Where the enclosure walls below the *horizontal assembly* have not less than a 3-hour *fire-resistance rating* with opening protectives in accordance with Section 716.5, the enclosure walls extending above the *horizontal assembly* shall be permitted to have a 1-hour *fire-resistance rating*, provided:

1. The *building* above the *horizontal assembly* is not required to be of Type I construction;
2. The enclosure connects fewer than four *stories*; and

3. The enclosure opening protectives above the *horizontal assembly* have a *fire protection rating* of not less than 1 hour.

4. *Stairways* permitted to be constructed of wood above the *horizontal assembly* are also permitted to be constructed of wood below the *horizontal assembly*. See Section 202 for the definition of *stairway*.

5. The *building* or buildings above the *horizontal assembly* shall be permitted to have any of the following occupancies:

5.1. Multiple Group A occupancy uses, each with an occupant load of less 300;

5.2. Group B;

5.3. Group I-1, Condition 2 licensed care facilities;

5.4. Group M;

5.5. Group R;

5.6. Group S-2 parking garage used for the parking and storage of private motor vehicles; and

5.7. Uses incidental to the operation or serving occupants of the *building* (including entry lobbies, mechanical rooms, storage areas and similar uses).

6. The building below the *horizontal assembly* is permitted to be any occupancy allowed by this code except Group H.

7. The maximum building height in feet (mm) shall not exceed the limits set forth in Section 504.3 for the *building* having the smaller allowable height as measured from the grade plane.

8. All portions of the *buildings* above and below the three-hour *horizontal assembly* shall be protected throughout with an *automatic sprinkler system* that complies with Section 903.3.1.1.

9. Occupied floors shall be not more than 75 feet above the lowest level of fire department vehicle access.

Interpretation ((~~I509.2~~)) I510.2: For the purpose of this item, occupied roof decks are considered floors used for human occupancy if the occupant load of the deck is 10 or more on the roof of a

building not equipped with an *automatic sprinkler system* or where the occupant load is 50 or more on the roof of a *building* that is equipped with an *automatic sprinkler system*.

10. Where the structure above the horizontal assembly is of Type V construction, and the structure or any portion of the structure is 7 stories above grade plane in height, all interior exit stairways shall be pressurized in accordance with Section 909.20 for low-rise stairways.

11. Where the structure above the horizontal assembly is not of Type V construction, interior exit stairways that connect more than 6 stories above the level of exit discharge for the stairway shall be pressurized in accordance with Section 909.20 for low-rise stairways.

* * *

~~((510.5))~~ **510.9 Group R-1 and R-2 buildings of Type IIIA construction.** The height limitation for *buildings* of Type IIIA construction in Groups R-1 and R-2 shall be increased to six *stories* and 75 feet (22 860 mm) where the first-floor assembly above the *basement* has a *fire-resistance rating* of not less than 3 hours and the floor area is subdivided by 2-hour fire-resistance-rated *fire walls* into areas of not more than 3,000 square feet (279 m2).

~~((510.6))~~ **510.5 Group R-1 and R-2 buildings of Type IIA construction.** The height limitation for buildings of Type IIA construction in Groups R-1 and R-2 shall be increased to nine *stories* and 100 feet (30 480 mm) where the building is separated by not less than 50 feet (15 240 mm) from any other building on the *lot* and from *lot lines*, the *exits* are segregated in an area enclosed by a 2-hour fire-resistance-rated *fire wall* and the first floor assembly has a *fire-resistance* rating of not less than 1 ½ hours.

~~((510.7))~~ **510.6 Open parking garage beneath Groups A, I, B, M and R.** *Open parking garages* constructed under Groups A, I, B, M and R shall not exceed the height and area limitations permitted under Section 406.5. The height and area of the portion of the *building* above the *open parking garage* shall not exceed the limitations in Section 503 for the upper occupancy. The height, in both feet and *stories*, of the

portion of the building above the *open parking garage* shall be measured from *grade plane* and shall include both the *open parking garage* and the portion of the *building* above the parking garage.

((510.7.1)) 510.6.1 Fire separation. *Fire barriers* constructed in accordance with Section 707 or *horizontal assemblies* constructed in accordance with Section 711 between the parking occupancy and the upper occupancy shall correspond to the required *fire-resistance rating* prescribed in Table 508.4 for the uses involved. The type of construction shall apply to each occupancy individually, except that structural members, including main bracing within the open parking structure, which is necessary to support the upper occupancy, shall be protected with the more restrictive fire-resistance-rated assemblies of the groups involved as shown in Table 601. *Means of egress* for the upper occupancy shall conform to Chapter 10 and shall be separated from the parking occupancy by *fire barriers* having not less than a 2-hour *fire-resistance rating* as required by Section 707 with *self-closing* doors complying with Section 716 or *horizontal assemblies* having not less than a 2-hour *fire-resistance rating* as required by Section 711, with *self-closing* doors complying with Section 716. *Means of egress* from the *open parking garage* shall comply with Section 406.5.

((510.8)) 510.7 Group B or M buildings with Group S-2 open parking garage above. Group B or M occupancies located below a Group S-2 *open parking garage* of a lesser type of construction shall be considered as a separate and distinct building from the Group S-2 *open parking garage* for the purpose of determining the type of construction where all of the following conditions are met:

1. The buildings are separated with a *horizontal assembly* having a *fire-resistance rating* of not less than 2 hours.
2. The occupancies in the building below the *horizontal assembly* are limited to Groups B and M.
3. The occupancy above the *horizontal assembly* is limited to a Group S-2 *open parking garage*.
4. The building below the *horizontal assembly* is of Type IA construction.

Exception: The *building* below the *horizontal assembly* shall be permitted to be of Type IB or II

construction, but not less than the type of construction required for the Group S-2 *open parking garage* above, where the *building* below is not greater than one story in height above grade plane.

5. The height and area of the *building* below the *horizontal assembly* does not exceed the limits set forth in Section 503.

6. The height and area of the Group S-2 open parking garage does not exceed the limits set forth in Section 406.5. The height, in both feet and stories, of the Group S-2 *open parking garage* shall be measured from grade plane and shall include the building below the *horizontal assembly*.

7. Exits serving the Group S-2 open parking garage discharge directly to a street or *public way* and are separated from the *building* below the *horizontal assembly* by 2-hour fire barriers constructed in accordance with Section 707 or 2-hour *horizontal assemblies* constructed in accordance with Section 711, or both.

~~((510.9))~~ 510.8 Multiple buildings above a horizontal assembly. Where two or more *buildings* are provided above the *horizontal assembly* separating a Group S-2 parking garage or *building* below from the *buildings* above in accordance with the special provisions in Section 510.2, 510.3 or ~~((510.8))~~ 510.7, the buildings above the *horizontal assembly* shall be regarded as separate and distinct buildings from each other and shall comply with all other provisions of this code as applicable to each separate and distinct *building*.

510.10 Group R-2 buildings of Type IIIA construction. The height limitation for *buildings* of Type IIIA construction in Group R-2 shall be increased to six *stories* and 75 feet (22 860 mm) where all of the following conditions are met:

1. The first story of Type IIIA construction is separated from stories above with a *horizontal assembly* having a *fire-resistance rating* of not less than 2 hours.

2. All stories of Type IIIA construction greater than 6,000 gross square feet shall be subdivided into compartments, by 2-hour fire-resistance rated *fire walls*, with areas of not more than 12,000 gross square feet.

3. Each compartment shall have an enclosed *exit access stairway*, and a standpipe system in accordance with Section 905.

4. Unprotected vertical openings, including unenclosed *exit access stairways*, shall not penetrate floor/ceiling assemblies between stories of Type IIIA construction or between stories of Type IIIA and Type IA construction.

5. Mezzanines shall not be allowed in any story of the Type IIIA construction.

6. The maximum total design *dead load* shall be 50psf for all roof areas above the sixth story of Type IIIA construction.

Note: The *dead load* shall be calculated as specified in Chapter 2 and Section 1607.12.3.1.

Note: The maximum total design *dead load* of 50psf is permitted to be applied over the entire roof area above the sixth story of Type IIIA construction.

Section 2. This ordinance shall take effect and be in force 30 days after its approval by the Mayor, but if not approved and returned by the Mayor within ten days after presentation, it shall take effect as provided by Seattle Municipal Code Section 1.04.020.

Passed by the City Council the _____ day of _____, 2018, and signed by me in open session in authentication of its passage this _____ day of _____, 2018.

President _____ of the City Council

Approved by me this _____ day of _____, 2018.

Jenny A. Durkan, Mayor

Filed by me this _____ day of _____, 2018.

Monica Martinez Simmons, City Clerk

(Seal)