

requirements in the fire code while providing building owners an appropriate period of time to achieve compliance; NOW, THEREFORE,

BE IT ORDAINED BY THE CITY OF SEATTLE AS FOLLOWS:

Section 1. Section 1103.2 of the 2012 Seattle Fire Code, as adopted by Section 22.600.020 of the Seattle Municipal Code, is amended as follows:

1103.2 Emergency responder radio coverage in existing high-rise buildings. Existing high-rise buildings that do not have a wired communication system or approved radio coverage for emergency responders within the building shall be equipped with such system or coverage within (~~two~~) four years from the effective date of the adoption of this code:

Exception:

1. A wired communication system in accordance with Section 907.2.13.2 may be provided in lieu of an approved radio coverage system.
2. Buildings and areas of buildings that have minimum radio coverage signal strength levels of the King County Regional 800 MHz Radio System within the building in accordance with Section 510.4.1 without the use of a radio coverage system.

Section 2. This ordinance shall take effect and be in force 30 days after its approval by the Mayor, but if not approved and returned by the Mayor within ten days after presentation, it shall take effect as provided by Seattle Municipal Code Section 1.04.020.

Passed by the City Council the ____ day of _____, 2015, and signed by me in open session in authentication of its passage this ____ day of _____, 2015.

President _____ of the City Council

Approved by me this ____ day of _____, 2015.

Edward B. Murray, Mayor

Filed by me this ____ day of _____, 2015.

Monica Martinez Simmons, City Clerk

(Seal)